

Murray City Sewer Utility Specifications & Requirements

Contacts:

Sewer: Danny Astill Mark Ackerman Phone: (801) 270-2440 Fax: (801)270-2450
Orson sharp

Mainline Sewer: PVC, (extruded as one piece or suitable equivalent)
Reinforced Concrete

Service Laterals: PVC
Cast Iron
Ductile Iron

Service Clean Out: PVC, Cast Iron and Ductile Iron Pipe
Cast Iron Wye required on all laterals
Cast Iron Clean Out Cap With Brass Lid required on all laterals

Murray City pipe bedding requirements;

6" of minimum bedding using 1 ½ " minus gravel size, and a minimum of pipe zone bedding to 6" above the pipe using 1 ½ " minus gravel size.

Anything that deviates from these requirements or does not meet these minimums must be approved by Murray City Personnel.

Testing;

All sewer laterals must meet a water test,

Murray City requires air tests on all main line pipe sections, to be performed by the contractor,

Murray City requires a TV inspection of the complete line after the contractor has completed and passes the air test. The TV inspection will be performed by Murray City personnel.